

Completion Certificate

1	Name of Scheme	-	Bhawan W/s Scheme, Block- Rajepur
2	Authority	-	Jal Nigam, Farrukhabad
3	Detail of Works	-	
(A)	Boundry Wall	-	1 No.
(B)	Staff Quarter	-	1 No.
(C)	Tube Well	-	1 No. (500 LPM / 10 HP)
(D)	Rising Main, Bye Pass Arrangement	-	27.00 Meter.
(E)	Over Head tank (OHT)	-	100 K.L./12 Meter.
(F)	Distribution System	-	
i	P.V.C. Pipe 6 Kg/ Cm ²	-	
	140mm Dia	-	107.00 Meter
	90mm Dia	-	2223.00 Meter
	75mm Dia	-	22.00 Meter
	63mm Dia	-	3785.00 Meter
ii	Sluice Valve 100 mm	-	1 Nos.
iii	Sluice Valve 80 mm	-	2 No.
(G)	House Connection	-	60 Nos.
(H)	Public Stand Post	-	07 Nos.

Handed Over

Manoj Kumar
(Manoj Kumar-I)
Junior Engineer

R. P. Jha
(R. P. Jha)
Assistant Engineer

Pankaj Kumar
12/03/18
(Pankaj Kumar Yadav)
Executive Engineer

No. 1223 / W-17 / 09

dated-12.03.2018

Quality Check Approval

12/03/18
EE (Tube Well)

12/03/18
DPRO

12/03/18
DDO

अधीक्षक
आयत अधिकारी

अनिल कुमार
(अनिल कुमार)

प्रधान
2. विभागाध्यक्ष
वि० एवं राजपुर (फर्रुखाबाद)