


GENERAL P.W.D. FORM NO. 12

(Reference to PWD code Paragraph 203 to 206)

1. On the completion of original works executed of behalf of another department completion certificate in general PWD form No. 12 (All PWD) and form No. 458 is hereby forwarded by the Executive Engineer to Civil or Military authorities concerned who will sign it in the space provided for the purpose vide also paragraph 205, and returned it to Executive Engineer, IXth Division, U.P. Jal Nigam, Saharanpur.
2. **COMPLETION CERTIFICATE OF ORIGINAL WORKS:-**
The counter signature of a civil or military officer surely complied and taken over and involve further responsibility are to be taken here below. If the counter signature office is not satisfied with the works and wished to make any remark can do so over his signature but should bear in mind that making with us necessary or irrelevant remarks may such a trouble and delay.

HANDED OVER


(NEERAJ KUMAR)
PROJECT MANAGER,
CONSTIT. UNIT U.P. JAL NIGAM,
SAHARANPUR.

TAKEN OVER

GRAM PRADHAN PATNI
BLOCK- SARSAWA
DISTT. SAHARANPUR

प्रधान क मती
ग्राम पंचायत पटनी न्याय पंचायत पटनी
क्षेत्र पंचायत सरसावा जिला सहारनपुर

**OFFICE OF THE PROJECT MANAGER, CONSTRUCTION UNIT, U.P. JAL NIGAM
SAHARANPUR.**

Name of work :	Patni village water supply Scheme Under ARWSP (Public Contribution)
Authority:	Managing Director, U.P. Jal Nigam Lucknow.
Estimated Cost :	For Amount of Rs. 78.65 lacs Year 2008-09
Place :	PATNI VILLAGE BLOCK – SARSAWA DISTRICT- SAHARANPUR
Details of Works :	Following Civil Works completed and to be handed over herewith.

1. PUMP HOUSE CUM CLORONOME One No

2. RISING MAIN WITH BYE PASS ARRANGEMENT:- Rising main has been laid from tube well to Over Head Tank, rising main has also been joined with over head tank 200 K.L.
150 mm dia C.I./D.I. Tyton pipe 23.00 M.

3. SLUICE VALVE :- C.I. Sluice Valve 50 mm to 200 mm. 15 Nos.


4. DISTRIBUTION SYSTEM:- Different size of pipe lines of followings also shown in attached completion plan has been laid
150 mm dia CI/DI pipe - 4800 m
160 MM DIAPVC- 240.00 m
140 MM DIA PVC- 120.00 m
110 MM DIA PVC- 475.00 m
90 MM DIA PVC- 732.00 m
63 MM DIA PVC- 7826.00 m


5. OVER HEAD TANK : 200 K.L. Capacity and 14 M. Staging. One No.


6. PUBLIC STAND POST 13 Nos.

7. DRAWINGS The completion plan of rising main, distribution system with above is enclosed herewith.

Certified that the works maintained above has been completed with remarks handed over on 30.6.2010 dated to The Gram Pradhan Village Patni, Block Sarsawa, Distt. Saharanpur and no deviation has been found in the work or material stated above.


(Surendra Singh)
JUNIOR ENGINEER
L. No.


(M.K. Niranjana)
ASSISTANT ENGINEER
Dated


(Neeraj Kumar)
PROJECT MANAGER
Construction Unit, U.P. Jal Nigam

Returned to the Project Manager Construction Unit U.P. Jal Nigam Saharanpur .
The works have been taken over by the Gram Pradhan Patni Block- Sarsawa, Distt. Saharanpur.

Gram Pradhan Patni
Block- Sarsawa Distt. Saharanpur.

प्रधान कमला
ग्राम पंचायत पटनी न्याय पंचायत पटनी
क्षेत्र पंचायत