



Name of Scheme		Taroli Water Supply Scheme					
Village	Taroli	Gram Panchayat:	Taroli	Block	Karchhana	District	Prayagraj
1	Meeting with GP, GPWSP and villagers					Yes	
2	Introduction about the project by AE DPMU					Yes	
3	Handing Over List of assets created in the project					Yes	
4	Joint inspection of assets created with Sarpanch/Pradhan and GPWSP					Yes	
	Source (Borewell or open well)					Borewell	
	Depth of source						
	Pump					12.5 HP/ 51 M.Head (1 Set+1 Spare)	
	Chlorinator					Yes	
	Length of pipe line						
	Pump main (Rising main)					35.00 M.	
	Distribution line					9.83 Km.	
	HH Connection given						
	OHSR (OHT)						
	Valve chambers					1 No. (125 KJ/14m.)	
	Technical sanction estimate along with drawings and other diagrams					21 No.	
	Original Agreement with BOQ					1 No.	
	Supplementary agreement if any					1 No.	
						Nil	
5	Joint Verification of Functionary scheme						
	LPCD					500 LPM	
	Quality/Chlorination unit					1 No.	
	pump					1 Set + 1 Spare	
	valves					21 No.	
	OHPS (OHT)					1 No. (125 KJ/14m.)	
6	Back to meeting after verification					Yes	
7	Discussion on activity to be performed by GPWSC					Yes	
	No of balance HH connection to be given					No.	
	O&M procedures					Yes	
	Social audit to be conducted					Yes	
	Detail of community contribution					Yes	
	Involvement of the core groups SHGs, NGOs, Youth					Yes	
	O&M cost estimation					Yes	
	User charges fixation and collection mechanism					Yes	
	Appointment of operator					Yes	
	O&M bank account					Yes	
8	Letter of Handing Over and Taking Over					Yes	
	Signed by AE and GPWSC (attached)					Yes	
	Signing of check list (Attached)					Yes	
9	Close of meeting with vote of tank					Yes	

  
AEUPJN  
Prayagraj

  
DINESH CHANDRA  
Technical Consultant & Secured Sarpanch/Secretary/Ward Member  
D.P.M.U.

