



100 mm dai	2no
80 mm dai	1no
65 mm dai	
50 mm dai	
Air valve 50 mm dia	1no
Fire Hydrant 80 mm dia	1no
Chambers with covers	
125 mm dai	
100 mm dai	
80 mm dai	
65 mm dai	
50 mm dai	
Air valve 50 mm dia	
Fire Hydrant 80 mm dia	
Tube well	
Source	Under Ground (Deep well)
Depth	161.m as per strata chart attached
Discharge/ Yield	1200 lpm
Quality of Water	Portable and O.K (Test report enclose)
Pumping Plant	25 HP ,1200 LPM and 55 m head 1 no and 1 no spare KSB make
Column pipe	150 mm dia 30 mts
Starter	1 set
SACADA system	
Stabiliser	1 set
Chlorinating Plant	1 no
Earting	Complete.
Electrification of Pump house	Complete.

  
 ग्राम पंचायत अधिकारी  
 ग्राम पंचायत  
 सि० ब० प्रतापपुर, प्रतापपुर



  
 Sd/-UPJN  
 Allahabad