


ANNEXURE -1: SUGGESTED HANDING OVER PROCESS

Name of Scheme		Sarai Hariram SVS water supply scheme	
Village Sarai Hariram	Gram Pnachayat Sarai Hariram	Block: pratappur	District – Prayagraj
1	Meeting with GP, GPWSP and Villagers	Yes	
2	Introduction about the project by AE, DPMU	Yes	
3	Handing Over list of assets created in the project	Yes	
4	Joint Inspection of assets created with Sarpanch/Pradhan and GPWSP	Yes	
	Source(Borwell or open well)	Borewell	
	Depth of Source	161 m	
	Pump	15 H.P.,55 M head	
	Chlorinator	700LPM(1 Set +1 spare)	
	Length of pipe line	1 set	
	Pump main (Rising main)		
	Distribution line	D.I. k-7,125mmdia,25M	
	HH Connection given	14134.0Meter	
	OHSR (OHT)	125nos	
	Valve chambers	1 no	
	Technical sanction estimate along with drawings and other diagrams	As per Index plan	
	Original Agreement with BOQ	1 no	
	Supplimentaryaggrement if any	Nil	
5	Joint Verification of Funcionary scheme		
	LPCD	700 lpm	
	Qualitly/ Chlorinaton unit	1 Set	
	Pump	1 set + 1 spare	
	Valves	As per Index plan	
	OHSR(OHT)	1 no. 150 kl,12 m	
6	Back to meeting after verification	Yes	
7	Discussion on activite to be performed by GPWSC	Yes	
	NO of balance HH connection to be given		
	O&M procedures	No	
	Social audit to be-conduced	Yes	
	Detail of community contribution	Yes	
	Involvement of the core groups: SHGs, NGOs, youth	Yes	
	O&M cost estimation	Yes	
	User charges fixation and collection mechanism	Yes	
	Appointment of operator	Yes	
	O&M bank account	Yes	
8	Letter of Hnading over and Taking over	Yes	
	Signed by AE and GPWSC (attached)	Yes	
	Sinning of check list (attached)	Yes	
9	Close of meeting with vote of thank	Yes	

A.E. UPJN
16/4/20


DINESH CHANDRA Sarpanch/Secretary/Ward member
 Technical Consultant & Pecurement
 D.P.M.U. Prayagraj 16.4.20

