

ANNEXURE-1: SUGGESTED HANDING OVER PROCESS

16/11

Name of Scheme		Amiliya Kanan Water Supply Scheme				
Village	Amiliya Kanan	Gram Panchayat	Amiliya Kanan	Block	Uruva	District Allahabad
1	Meeting with GP, GPWSP and villagers					Yes
2	Introduction about the project by AE DPMU					Yes
3	Handing Over List of assets created in the project					Yes
4	Joint Inspection of assets created with Sarpanch/Pradhan and GPWSP					Yes
	Source (Borewell or open well)					Yes
	Depth of source					Yes
	Pump					Yes
	Chlorinator					Yes
	Length of pipe line					
	Pump main (Rising main)					349.00 M.
	Distribution line					17.450 Km.
	HH Connection given					230
	OHSR (OHT)					1 No. (450 KI/18m.)
	Valve chambers					14 No.
	Technical sanction estimate along with drawings and other diagrams					1 No.
	Original Agreement with BOQ					2 No.
	Supplimentary aggrement if any					Nil
5	Joint Verification of Funcionary scheme					
	LPCD					
	Quality/Chlorination unit					2 Set
	pump					2 Set + 1 Spare
	valves					15 No.
	OHPS (OHT)					1 No. (450 KI/18m.)
6	Back to meeting after varification					Yes
7	Discussion on activity to be performed by GPWSC					Yes
	No of balance HH connection to be given					1046
	O&M procedures					NO
	Social audit to be conduced					Yes
	Detail of community contribution					Yes
	Involvement of the core groups SHGs, NGOs, Youth					Yes
	O&M cost estimation					Yes
	User charges fixation and collection mechanism					Yes
	Appointment of operator					Yes
	O&M bank account					NO
8	Letter of Handing Over and Taking Over.					Yes
	Signed by AE and GPWSC (attached)					Yes
	Sinning of check list (Attached)					Yes
9	Close of meeting with vote of tank					Yes

AEUP/JN
Allahabad

[Signature]

[Signature] Surpanch/Secretary/Ward Member
 गांधी नगर पंचायत
 गांधी नगर, देवा-इलाहाबाद
 दिनांक 16/11/2010

1h