


ANNEXURE -1: SUGGESTED HANDING OVER PROCESS

Name of Scheme		Amoura SMV water supply scheme	District -- Prayagraj
Village : Amoura		Gram Pnachayat Amoura	Block: Saidabad
			Yes
1	Meeting with GP, GPWSP and Villagers		Yes
2	Introduction about the project by AE, DPMU		Yes
3	Handing Over list of assets created in the project		Yes
4	Joint inspection of assets created with Sarpanch/Pradhan and GPWSP		Borewell
	Source(Borwell or open well)		160 m
	Depth of Source		55 M head (1 Set)
	Pump		1 no
	Chlorinator		
	Length of pipe line		38.5 m
	Pump main (Rising main)		13.18 km
	Distribution line		327
	HH Connection given		1 no
	OHSR (OHT)		As per Index plan
	Valve chambers		
	Technical sanction estimate along with drawings and other diagrams		1 no
	Original Agreement with BOQ		Nil
	Supplimentary aggrement if any		
5	Joint Verification of Funcionary scheme		1200 lpm
	LPCD		1 Set
	Qualiltly/ Chlorinaton unit		1 set
	Pump		As per Index plan
	Valves		1 no. 150 kl,12 m
	OHSR(OHT)		Yes
6	Back to meeting after verification		Yes
7	Discussion on activite to be performed by GPWSC		nill
	NO of balance HH connection to be given		Yes
	O&M procedures		Yes
	Social audit to be conduced		Yes
	Detail of community contribution		Yes
	Involvement of the core groups: SHGs, NGOs, youth		Yes
	O&M cost estimation		Yes
	User charges fixation and collection mechanism		Yes
	Appointment of operator		Yes
	O&M bank account		Yes
8	Letter of Hnading over and Taking over		Yes
	Signed by AE and GPWSC (attached)		Yes
	Sinning of check list (attached)		Yes
9	Close of meeting with vote of thank		

A.E. UPJN


 Sirpanch/Secretary/Ward member
 विलासपुर
 ग्राम प्रधान
 ग्राम पंचायत अमौरा
 तिमखो-सैदाबाद इलाहाबाद