


ANNEXURE -1: SUGGESTED HANDING OVER PROCESS

Name of Scheme		Jamua SMV water supply scheme	
Village: Jamua		Gram Panchayat : Jamua	Block: Bahariya District -- Prayagraj
1	Meeting with GP, GPWSP and Villagers		Yes
2	Introduction about the project by AE, DPMU		Yes
3	Handing Over list of assets created in the project		Yes
4	Joint inspection of assets created with Sarpanch/Pradhan and GPWSP		Yes
	Source (Borwell or open well)		Borewell
	Depth of Source		182 m
	Pump		55 M head (1 Set +1 spare)
	Chlorinator		1 no
	Length of pipe line		
	Pump main (Rising main)		
	Distribution line		
	HH Connection given		
	OHSR (OHT)		1 no
	Valve chambers		As per Index plan
	Technical sanction estimate along with drawings and other diagrams		
	Original Agreement with BOQ		1 no
	Supplimentary aggrement if any		Nil
5	Joint Verification of Funcionary scheme		
	LPCD		600 lpm
	Qualilty/ Chlorinator unit		1 Set
	Pump		1 set + 1 spare
	Valves		As per Index plan
	OHSR(OHT)		1 no. 100 kj, 14 m
6	Back to meeting after verification		Yes
7	Discussion on activite to be performed by GPWSC		Yes
	NO of balance HH connection to be given		
	O&M procedures		Yes
	Social audit to be conduced		Yes
	Detail of community contribution		Yes
	Involvement of the core groups: SHGs, NGOs, youth		Yes
	O&M cost estimation		Yes
	User charges fixation and collection mechanism		Yes
	Appointment of operator		Yes
	O&M bank account		Yes
8	Letter of Hnading over and Taking over		Yes
	Signed by AE and GPWSC (attched)		Yes
	Sinning of check list (attched)		Yes
9	Close of meeting with vote of thank		


A.E. UPJN


Sirpanch/Secretary/Ward member